

July 27, 2015

Chief Robert Farris
Stevenson Fire Department
7121 Loop Rd, PO Box 371
Stevenson, Washington 98648

Chief Farris:

The Washington Surveying and Rating Bureau (WSRB) have completed its evaluation of the fire protection capabilities, as they relate to fire insurance rating, of your community. We wish to inform you that the Protection Classification (PC) for Stevenson has remained a Protection Class 6

A Protection Class (PC) 6 rating will apply to dwelling and commercial properties located in the community, within 5 road miles of a responding fire station and having standard fire hydrant distribution and water supply. Properties in the community not meeting the above requirements will receive a different PC rating.

The issue that was detailed in our June 24, 2015 letter has been resolved. Fire Station 21 at 2021 Loop Road will continue to be recognized for insurance rating purposes.

We wish to thank you and Karl Russell for the cooperation during the evaluation.

Please find enclosed a copy of the new Protection Class Report. This report shows the various items evaluated and points associated with each item. The points total for all items determines the Protection Class of the community.

This survey was not conducted for property loss prevention or for life safety purposes. The purpose was to gather information needed to determine a fire insurance relevant Public Protection Classification that may be used to develop fire insurance rates or loss costs. Our evaluation criteria incorporate many national recognized standards, such as those developed by NFPA and AWWA, and has been filed with and approved by the Washington State Office of Insurance Commissioner.

If you have any questions, please let us know.

Sincerely,



Eric Cunningham
Public Protection Field Representative
Seattle Office 206.273.7183
eric.cunningham@wsrb.com
Enclosure

cc: Mayor of City of Stevenson