

Stevenson WW Facility Plan/General Sewer Plan
 Description of Alternatives
 May 18, 2017

	Alt 1B Minimal Pretreatment (20% BOD Removal) Conventional Activated Sludge	Alt 2 Pretreatment to Domestic Strength (85% BOD Removal) Oxidation Ditch
Pretreatment (by Others)	High load dischargers construct aerated equalization tanks	High load dischargers construct aerobic or anaerobic package treatment system at central location
Headworks	Construct new headworks, including: <ul style="list-style-type: none"> • Grit removal • Fine screens • Flow measurement 	Construct new headworks, including: <ul style="list-style-type: none"> • Fine screens • Flow measurement
Secondary Treatment	Convert to conventional activated sludge treatment: <ul style="list-style-type: none"> • Construct 2 new conventional activated sludge aeration basins, with space for 3rd basin • Convert oxidation ditch to 3 anoxic selector basins • Construct new building for aeration blowers Add 3 rd clarifier	Expand oxidation ditch treatment: <ul style="list-style-type: none"> • Construct 1 new oxidation ditch with anoxic selector, with space for 3rd ditch • Add anoxic selector to existing oxidation ditch Add 3 rd clarifier
Disinfection	Expand UV disinfection: <ul style="list-style-type: none"> • Construct 2nd parallel UV channel • Install new UV lamps in both channels 	Expand UV disinfection: <ul style="list-style-type: none"> • Construct 2nd parallel UV channel • Install new UV lamps in both channels
Solids Handling	Upgrade existing solids handling facilities: <ul style="list-style-type: none"> • Refurbish solids holding tank with new partition walls and new aeration system • Construct new solids handling/blower building • Install new mechanical sludge thickener • Install new sludge pumps and truck loading station 	Upgrade existing solids handling facilities: <ul style="list-style-type: none"> • Refurbish solids holding tank with new partition walls and new aeration system • Construct new solids handling/blower building • Install new mechanical sludge thickener • Install new sludge pumps and truck loading station
Support Facilities	Upgrade electrical and control systems, including: <ul style="list-style-type: none"> • New SCADA control system • Replace emergency generator with larger generator Construct new shop, operations, and lab building	Upgrade electrical and control systems, including: <ul style="list-style-type: none"> • New SCADA control system • Replace emergency generator with larger generator Construct new shop, operations, and lab building

Stevenson WW Facility Plan/General Sewer Plan
 Comparison of Alternatives
 May 18, 2017

	Alt 1B Minimal Pretreatment (20% BOD Removal) Conventional Activated Sludge	Alt 2 Pretreatment to Domestic Strength (85% BOD Removal) Oxidation Ditch
Capital Cost – City Wastewater Treatment Plant	\$12,183,000	\$10,205,000
Capital Cost – Pretreatment Facilities by Others	\$711,000	\$2,444,000
Capital Cost – City and Others	\$12,894,000	\$12,649,000
Plant Operation FTEs (year 2040, CH2M and City effort combined)	3.5	3.0
Major Considerations	Larger treatment capacity (greater total number of ERUs)	Smaller treatment capacity (reduced total number of ERUs)
	Accommodates industrial/commercial growth best	
		Simpler to operate
	Maximizes treatment capacity on existing site	
	Preserves waterfront aesthetics	
		Lower solids production and lower solids disposal costs
	Easier to achieve 20% pretreatment	Administratively complex to enforce 85% pretreatment
	Pretreatment program and BOD monitoring required	Pretreatment program and BOD monitoring required
	High strength surcharge for high-load dischargers	